

# Enterprise



4815 GRIMSBY DR.  
SAN JOSE, CALIFORNIA 95130  
TEL.: (408) 866-7800  
FAX: (408) 378-8136

## Engineering Laboratory, Inc.

November 1, 2004

File # 0357

Won-Door Corporation  
1865 South 3480 West  
Salt Lake City, Utah 84104

Attention: Mr. Carl Goodman  
Subject: "Fireguard" Horizontal Sliding Fire Door Assembly  
Reference: International Building Code, 2003 Edition

Dear Mr. Goodman:

As requested I have reviewed the Won-Door Corporation "Fireguard", 20/60/90/180 Horizontal Sliding Fire Door Assembly tested in Enterprise Engineering Laboratory Inc. Test Report # 92-357-2-TR1 and listed in International Code Council, Evaluation Service Report # 3890, for conformance to the current requirements of Sections 710.5.2, 715.3.3, 715.3.5.1 and 715.3.5.3 of the International Building Code, 2003 Edition..

The subject assembly was found to comply with all requirements of the above mentioned code sections and also complies with the requirements of UL 1784 for Smoke and Draft Control Assemblies. The detailed test data is contained in Enterprise Engineering Laboratory, Inc., Test Report # 92-357-2-TR1, dated 7-8-1993

Should you have any questions in regard to this matter, please contact me at 408/866-7800.

Sincerely,  
Enterprise Engineering

B. C. Robnett  
General Manager

BCR/sg